Submitted to:

# Quarterly Report

**April 1, 2012 – June 30, 2012**

# Fluid Bed Incinerator O&M
# East Bank WWTP
# of the
# Sewerage and Water Board
# Of New Orleans

**Air Permit # 2140-00089-V2, AI#4859**
**NPDES Permit#LA0038091, Solid Waste Permit # P-071-4582; P-0329**

VEOLIA WATER

Sewerage & Water Board of New Orleans

VEOLIA
WATER

July 6, 2012

Marcia St. Martin
Director N.O. S&WB
S&WB of New Orleans
625 St. Joseph Street
New Orleans, LA 70130

Re: Quarterly Report – Fluid Bed Incineration, Operation and Maintenance

Dear Ms. St. Martin:

The enclosed report satisfies all conditions set forth in the Fluid Bed Incinerator's Operations and Maintenance Plan. The report is in accordance with 40 CFR Part 60, Subpart A&O; 40 CFR Part 60, Subpart A, δ60.7 and 40 CFR Part 503; 40 CFR Part 61, Subpart C and E.

Additionally, this report satisfies paragraphs 15, 16, and 64 B of the Consent Decree (DOJ case no. 90-5-1-4043). Thereby, verifying that the operation and maintenance of the Fluid Bed Incinerator (FBI) was in accordance with the FBI's interim O&M Plan previously submitted.

**Please be aware that the Fluid Bed Incinerator was off-liine for the majority of the second quarter of 2012 due to the catastrophic failure of the unit's heat exchanger. The replacement heat exchanger was delivered to the plant site on June 8th and incineration began on June 18th, 2012.**

I certify that the information contained in or accompanying this document is true, accurate, and complete. As to those identified portions of this document for which I cannot personally verify, I certify as acting official having supervisory responsibility for the persons who, acting under my direct instructions, made the certification, that this is true, accurate, and complete.

If any questions arise during the review of this report, please do hesitate to contact me at 504-277-5400.

Sincerely,

K. Servat

Kevin Servat
Project Manager
Veolia Water, New Orleans

Veolia Water North America Operating Services, LLC
6501 Florida Avenue, New Orleans, LA 70117
Tel: 504.277.5400 • Cell: 504.628.2628
www.veoliawaterna.com