

SEWERAGE & WATER BOARD OF NEW ORLEANS

DRAINAGE OPERATIONS

STATION	Address	Neighborhood	PUMPING EQUIPMENT															POWER EQUIPMENT				Pump Capacity (cfs)			6/22/18 9:00 AM		
			550	550	1000	1000	1100	1100	1100	225	225	60	15	312 KW	100 KW	25 Hz Power	60 Hz Power	Station Nominal Capacity (CFS)	Total No. of Pump(s)	No. of Pumps out	Station Nominal Capacity (CFS)	No. of Pump(s) Available	Operational Capacity (approx.)				
1	2501 S. Broad	Broadmoor	550	550	1000	1000	1100	1100	1100	225	225	60	15	312 KW	100 KW	4625	2200	6,825	11	1	6,765	10	99%				
2	444 N. Broad	Mid-City	550	550	1000	1000	1000	1000	1000	225	25	25	100 KW	House Gen	3150		3,150	6	0	3,150	6	100%					
3	2251 N. Broad	St. Bernard	550	550	1000	1000	1000	1000	1000	40	40	40	40	80 KW	125 KW	4260		4,260	9	0	4,260	9	100%				
4	5700 Warrington	Gentilly	12' A	12' B	14' C	14' D	14' E	14' F	3' CD-1-L	3' CD-1-R	3' CD-2-L	3' CD-2-R	House Gen	House Gen	3080	640	3,720	6	1	2,720	5	73%					
5	4841 Florida	Lower Nine	8' #1*	8' #2*	14' C	14' D	14' E	14' F	3' CD	3' CD-1-R	3' CD-2-L	3' CD-2-R	House Gen	TGI	1260	600	1,860	8	0	1,860	8	100%					
6	345 Orpheum	Lakeview	12' A	12' B	14' C	14' D	14' E	14' F	14' G	3' CD-1	3' CD-2	3' CD-2#2	3750 KW	3750 KW	6380	3200	9,580	15	0	9,580	15	100%					
7	5741 Orleans	City Park	11' #1*	11' #2*	6' #1V*	6' #2V*	6' #3V*	6' #4V*	6' #5V*	6' #6V*	6' #7V*	6' #8V*	3 MW	400 KW	1690	1000	2,690	5	0	2,690	5	100%					
10 "Claus"	9600 Hayne	N.O. East	250	250	250	250	250	250	250	250	250	250	2 MW	2 MW	1000		1,000	4	0	1,000	4	100%					
11	5301 E. Sixth	Lower Coast Algiers	250	250	250	250	250	250	250	250	250	250	500 KW	400 KW	500	1170	1,670	5	0	1,670	5	100%					
12	7223 Ponchartrain	West End	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	25 Hz GEN	60 Hz GEN	1000		1,000	1	0	1,000	1	100%					
13	4201 Tall Spruce	Algiers	250	250	50	1000	1000	1050	1050	1050	1050	1050	230 KW	230 KW	4650		4,650	7	2	2,650	5	57%					
14 "Jahacker"	12200 Hayne	N.O. East	300	300	300	300	300	300	300	300	300	300	2665 KW	House Gen	1200		1,200	4	0	1,200	4	100%					
15 "Int Coast"	Ibwy and Intracoastal Dr.	N.O. East	250	250	250	250	250	250	250	250	250	250	45 KW	House Gen	750		750	3	1	500	2	67%					
16 "St Charles"	7200 Wales	N.O. East	290	290	290	290	290	290	290	290	290	290	2665 KW	House Gen	1160		1,160	4	0	1,160	4	100%					
17 "D"	2801 Peoples	St. Roch	150	150	150	150	150	150	150	150	150	150	6000 KW	6000 KW	300		300	2	0	300	2	100%					
19	4500 Florida	Bywater	310	310	1100	1100	1100	1100	1100	1100	1100	1100	FC 3	FC 4	3920		3,920	5	0	3,920	5	100%					
20 "AMMD"	6300 Intercoastal Waterway	N.O. East	250	250	250	250	250	250	250	250	250	250	1500 KW	200 KW	500		500	2	0	500	2	100%					
1-10	101 Academy Dr.	1-10	250	250	250	250	250	250	250	250	250	250	2350 KW	2350 KW	850		850	4	0	850	4	100%					
Pritchard	2901 Monticello	Hollygrove	125	125	3	3	3	3	3	3	3	3	1285 KW	House Gen	253		253	3	0	253	3	100%					
18 "Masen"	Fontenot Lavee off Alcee Fortier	N.O. East	62	62	62	62	62	62	62	62	62	62	60 Hz GEN	House Gen	124		124	2	0	124	2	100%					
Dwyer	5700 Dwyer	N.O. East	356	356	356	356	356	356	356	356	356	356	3 MW	House Gen	1068		1,068	3	0	1,068	3	100%					
Elaïne	3100 Elaïne	N.O. East	45	45	45	45	45	45	45	45	45	45	60 Hz GEN	House Gen	90		90	2	0	90	2	100%					
Grant	3100 Grant	N.O. East	8	8	8	8	8	8	8	8	8	8	172		172		172	6	0	172	6	100%					
Oleander	9400 Oleander	Hollygrove	33	33	33	33	33	33	33	33	33	33	99		99		99	3	0	99	3	100%					
PPC	8800 S. Claiborne	Hollygrove	3750 KW	FC	Constant Duty	875	153	1,028	21	2	938	19	91%														
CFC	Earhart & Camborne	Hollygrove	6000 KW	2500 KW	8.5 MW (25 Hz)	2450	25313	49,863	99	3	46,643	96	94%														
			FC 1	FC 2	TG	TOTAL	25945	24946	50,891	120	5	47,581	115	93%													
Underpass 1	BAY ST. & RAILROAD (may not be returned to service - railroad culvert)	BAY STREET Pedestrian Underpass	0.18	0.18									0.36		2	2	0.00	0	0	0	0	0%					
Underpass 2	5600 CANAL BLVD.	CANAL BLVD	10	10	10	10	10	10	10	10	10	10	30		3	0	30	3	0	30	3	100%					
Underpass 3	2251 N. BROAD ST.	DPS 3 UP Broad	14	14									28		2	1	14	1	1	14	1	50%					
Underpass 4	5740 ORLEANS AVE.	DPS 7 UP Marconi	5	5									10		2	0	10	2	0	10	2	100%					
Underpass 5	3000 FRANKLIN AVE.	FRANKLIN AVE.	24	24									48		2	0	48	2	0	48	2	100%					
Underpass 6	HOSPITAL ST. & I-610	HOSPITAL ST.	6	6									12		2	0	12	2	0	12	2	100%					
Underpass 7	4601 S. CARROLLTON AVE.	NEW CARROLLTON	7	7									14		2	0	14	2	0	14	2	100%					
Underpass 8	4600 CARROLLTON AVE.	OLD CARROLLTON	7	7									21		3	0	21	3	0	21	3	100%					
Underpass 9	3100 PARIS AVE.	PARIS AVE.	24	24									72		3	0	72	3	0	72	3	100%					
Underpass 10	PONTCHARTRAIN BLVD. & RAILROAD	PONTCHARTRAIN	13	13									39		3	0	39	3	0	39	3	100%					
Underpass 11	PRESS DR. & LEON C. SIMON	PRESS DR.	33	33									99		3	0	99	3	0	99	3	100%					
Underpass 12	3300 ST. BERNARD AVE.	ST. BERNARD AVE.	10.5	10.5									21		2	0	21	2	0	21	2	100%					
			Underpass Pumps	38	356.36	394	29	3	380	26	96%																

Service Status
 Returned to service after 8/5
 Out of service
 Operational equipment
 Removed from service

Type of Equipment
 25 Hz equipment
 60 Hz equipment
 Permanent generators - with the exception of one permanent generator at DPS 11, all permanent generator equipment is 60 Hz
 Frequency changing equipment